UES Project No: 3310.2300528.0000
Workorder No: 318704-10
Report Date: 02/22/2024

607 Northwest Commodity Cove, Port St. Lucie, FL 34986 - P: 772-924-3575 - F: 772-924-3580

In-Place Density Test Report

Client: B & B Site Development, Inc.
1505-C South Parrott Avenue
Okeechobee, FL 34974

UES Technician: Sebastian Marsan
Date Tested: 12/27/2023

Project: Lakefront Estates - Vertical
27182 East SR 78, Okeechobee, Okeechobee County, FL 34974

Area Tested: Lot 479 & 480 Duplex - 27182 East State Road, Okeechobee

Material: Fill

Reference Datum: 0 = Top of Fill

Type of Test:

Field: ASTM D-6938 Nuclear Gauge Method

Laboratory: ASTM D1557 Modified Proctor

The tests below meet the 95% minimum compaction requirement.

Test No.	Location of Test	Range	Maximum Density (pcf)	Optimum Moisture (%)	Field Dry Density (pcf)	Field Moisture (%)	Soil Compaction (%)	Pass or Fail
28	Southeast Corner of Duplex Pad	0-1 ft	113.6	11.0	112.1	12.2	99	Pass
29	North Center of Duplex Pad	0-1 ft	113.6	11.0	112.6	12.3	99	Pass
30	Northwest Corner of Duplex Pad	0-1 ft	113.6	11.0	111.7	11.4	98	Pass
115	South Center of Duplex Pad	1-2 ft	113.6	11.0	111.0	11.1	98	Pass
116	Southwest Corner of Duplex Pad	1-2 ft	113.6	11.0	111.2	11.9	98	Pass
117	Northeast Corner of Duplex Pad	1-2 ft	113.6	11.0	111.3	11.6	98	Pass

Reviewed By
GFA International, Inc
FBPE Registry No.4930



Digitally signed by Allan G Abubakar
Date: 2024.02.22 15:52:31 -05'00'

Allan G. Abubakar, P.E.

STATE OF FLORIDA
Professional Engineer No. 69952

This item has been digitally signed and sealed by Allan G. Abubakar, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

To establish a mutual protection to Universal's clients, the Public and ourselves, all reports are submitted as confidential property of our clients and authorization for publication of statements, conclusions or extracts from or regarding Universal's reports is reserved pending our written approval.