






TYPICAL MASONRY CONTROL/EXPANSION JOINT DETAIL


NOTES:
1. PROVIDE EXPANSION JOINT IN ACCORDANCE WITH PLANS. OTHERWISE THE FOLLOWING CRITERIA SHALL BE MET:
   - A. AT 1.5 X WALL HEIGHT (25'-0" O.C. MAX)
   - B. AT CHANGES IN WALL HEIGHTS.
   - C. INTERSECTIONS OF WALLS WITH COLUMNS, PIERS AND PILASTERS.
   - D. AT CORNERS.
   - E. NO CLOSER THAN 2'-0" TO EDGE OF ANY OPENING IN WALL
   - F. WALL THICKNESS CHANGES
   - G. SLAB CONTROL JOINTS
2. REFER TO ARCHITECTURAL DRAWINGS FOR LOCATIONS OF ALL CONTROL JOINTS IN BRICK FACADE.



BOND BEAM ALIGNED ON BOTH SIDES OF THE COLUMN




BOND BEAM NOT ALIGNED ON BOTH SIDES OF THE COLUMN



THIS DETAIL SHALL ONLY BE USED WHEN A CONTROL JOINT IS CALLED OUT AND LOCATED NEXT TO AN OPENING ON THE CONTROL JOINT PLAN.

MASONRY CONTROL JOINT AT OPENING DETAIL



BOND BEAM INTERSECTION DETAIL

JT ENGINEERING
Building Solutions
1321 Brunswick Ave, Lawrence, NJ 08648
161 Washington Street, 13th Floor, Suite 1375 Conshohocken, PA 19428
P: 609.303.0236
F: 609.303.0237
www.jt-pe.com

JASON C. TARANTINO
Jason Tarantino
Digitally signed by Jason Tarantino
Date: 2023.12.26 17:27:20 -05'00'

FLORIDA LICENSE: PE 94381

ISSUED FOR PERMIT

REVISIONS:

Mk	DATE:	REMARKS
1	12/08/23	ISSUED FOR PERMIT

PROJECT:
Proposed Building
Okeechobee (Shul)
FL-78 & Access Road
Okeechobee, Florida, 34978

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE ORIGINAL AND UNPUBLISHED WORK OF THE ENGINEER. THE REPRODUCTION OF THIS DRAWING FOR THE PURPOSE OF COPYING THIS WORK OR REVISING SAID DRAWING SHALL BE CONSIDERED A VIOLATION OF BOTH THE PROFESSIONAL CODE OF ETHICS AND A THEFT OF COMPANY ASSETS, BOTH OF WHICH SHALL BE PROSECUTED TO THE FULLEST EXTENT OF CURRENT STATUTES.

DRAWING TITLE:
TYPICAL MASONRY WALL DETAILS

DRAFTED BY: NAR
REVIEWED BY: JCT
PROJECT NUMBER: 2318_05
DRAWING SCALE: AS NOTED
DRAWING NUMBER:
S532

AUTODESK