UNIVERSAL ENGINEERING SCIENCES®

Grounded in Excellence

Geotechnical Engineering
Construction Materials Testing & Inspec
Building Code Compliance
Occupational Health & Safety
Environmental
Building Envelope

Report of Rebound Hammer Test of Concrete
ASTM C805

Project: Lakefront Estates
Project ID: 3310.2500137.0000
Address: East SR 78, Okeechobee, FL
Report ID: 379141-1
Client: Amboy Builders LLC
Technician: Sam Albaz
Date Concrete Poured: 12/20/2024
Design Strength (PSI): 4000
Placement Location: Slab On Grade
Date Tested: 5/20/2025
Comments: 10 readings were recorded per location.

Test No.	Location	Average Impact Reading	Indicated PSI
1	Lot 438 at Northwest bedroom	43	5,100
2	Lot 517 at Living room	42	5,900

Respectfully Submitted.
GFA INTERNATIONAL, INC.
FBPE CA # 4930

ALLAN G. ABUBAKAR LICENSE No. 69952 STATE OF FLORIDA PROFESSIONAL ENGINEER

Digitally signed by Allan G Abubakar
Date: 2025.05.23 09:00:49 -04'00'

Allan G. Abubakar, P.E.
Professional Engineer # 69952
State of Florida

This item has been digitally signed and sealed by Allan G. Abubakar, P.E., on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.

*Testing done in general accordance with ASTM C805

*Test report shall not be reproduced, except in full, without the written approval of GFA International