Dobbs Enterprises, LLC

April 23, 2026

Glades County
Attn: Larry Factor, Public Safety Chief of Operations
500 Avenue J SW, PO Box 1527
Moore Haven, FL 33471

Subject: **Lakefront Fire Protection System**

Dear Mr. Factor:

I have personally prepared two fire flow test onsite at Lakefront and witnessed 4 others. Each test performed well above 1,000 gpm for each hydrant. Based on the attached flow test, it is my professional opinion there is sufficient fire protection and hydrant availability for the proposed buildings.

Should you have any questions or comments, please do not hesitate to call.

Sincerely,

Steven L. Dobbs Engineering



Steven L. Dobbs, P. E.
President

CC: Lakefront
File



1062 Jakes Way, Okeechobee, FL 34974
Phone: (863) 824-7644 **Cell:** (863) 634-0194
Email: sdobbspe@gmail.com