# Report of Rebound Hammer Test of Concrete
# ASTM C805

**Project:** Lakefront Estates
**Project ID:** A25153.00138
**Address:** East SR 78, Okeechobee, FL
**Report ID:** 390159
**Client:** Amboy Builders LLC
**Technician:** V.R.
**Date Concrete Poured:** u/k
**Design Strength (PSI):** 4000
**Placement Location:** Slab on Grade
**Date Tested:** 8/25/2025
**Comments:** 10 readings were recorded per location.

| Test No. | Location | Average Impact Reading | Indicated PSI |
|---|---|---|---|
| 1 | Lot 404 - permit number: 2500271 | 36 | 4600 |
| 2 | Lot 405 - permit number: 2500272 | 34 | 4300 |
| 3 | Lot 451 - permit number: 2500257 | 36 | 4600 |
| 4 | Lot 454 - permit number: 2500259 | 34 | 4300 |
| 5 | Lot 455 - permit number: 2500260 | 36 | 4600 |
| 6 | Lot 456 - permit number: 2500261 | 36 | 4600 |
| 7 | Lot 457 - permit number: 2500262 | 38 | 5000 |

Respectfully Submitted.
**GFA INTERNATIONAL, INC.**
FBPE CA # 4930




Digitally signed by Allan G Abubakar
Date: 2025.08.26 15:12:38 -04'00'

Allan G. Abubakar, P.E.
Professional Engineer # 69952
State of Florida

*Testing done in general accordance with ASTM C805

*Test report shall not be reproduced, except in full, without the written approval of GFA International