# Report of Rebound Hammer Test of Concrete
# ASTM C805

**Project:** Lakefront Estates
**Project ID:** 3310.2500137.0000
**Address:** East SR 78, Okeechobee, FL
**Report ID:** 379141-2
**Client:** Amboy Builders LLC
**Technician:** Sam Albaz
**Date Concrete Poured:** 12/23/2024
**Design Strength (PSI):** 4000
**Placement Location:** Slab On Grade
**Date Tested:** 5/20/2025
**Comments:** 10 readings were recorded per location.

| Test No. | Location | Average Impact Reading | Indicated PSI |
|---|---|---|---|
| 1 | Lot 516 at South footing | 42 | 5,400 |
| 2 | Lot 525 at Living room | 42 | 5,900 |
| 3 | Lot 526 at Living room | 41 | 5,700 |
| | | | |

Respectfully Submitted.
**GFA INTERNATIONAL, INC.**
FBPE CA # 4930

ALLAN G. ABUBAKAR LICENSE No. 69952 STATE OF FLORIDA PROFESSIONAL ENGINEER

Digitally signed by Allan G Abubakar
Date: 2025.05.23 09:02:44 -04'00'

Allan G. Abubakar, P.E.
Professional Engineer # 69952
State of Florida

This item has been digitally signed and sealed by Allan G. Abubakar, P.E., on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.

*Testing done in general accordance with ASTM C805

*Test report shall not be reproduced, except in full, without the written approval of GFA International