Report of Rebound Hammer Test of Concrete
ASTM C805

Project: Lakefront Estates
Project ID: A25153.00138
Address: East SR 78, Okeechobee, FL
Report ID: 390159
Client: Amboy Builders LLC
Technician: V.R.
Date Concrete Poured: u/k
Design Strength (PSI): 4000
Placement Location: Slab on Grade
Date Tested: 8/25/2025
Comments: 10 readings were recorded per location.

Test No.	Location	Average Impact Reading	Indicated PSI
1	Lot 461 - permit number: 2500245	32	3900
2	Lot 462 - permit number: 2500256	34	4300
3	Lot 463 - permit number: 2500255	34	4300
4	Lot 464 - permit number: 2500254	34	4300
5	Lot 465 - permit number: 2500253	38	5000
6	Lot 466 - permit number: 2500252	38	5000
7	Lot 467 - permit number: 2500251	38	5000

Respectfully Submitted.
GFA INTERNATIONAL, INC.
FBPE CA # 4930



Digitally signed by Allan G Abubakar
Date: 2025.08.26 15:13:22 -04'00'

Allan G. Abubakar, P.E.
Professional Engineer # 69952
State of Florida

*Testing done in general accordance with ASTM C805

*Test report shall not be reproduced, except in full, without the written approval of GFA International